



केन्द्रीय विद्युत विनियामक आयोग
CENTRAL ELECTRICITY REGULATORY COMMISSION



Harpreet Singh Pruthi
Secretary

No.RA-14026(11)/3/2019-CERC

Dated: 02 December, 2022

Shri N R Narasimhan
Chairman and Managing Director
Grid Controller of India Ltd. (Grid-India)
B-9 1st Floor,
Qutub Institutional Area,
Katwaria Sarai,
New Delhi - 110016


Subject: Detailed Procedure on interim methodology for estimation of Reserves under CERC (Ancillary Services) Regulations, 2022

Sir,

This has reference to Grid-India's (formerly known as POSOCO) letter no. POSOCO/NLDC/2022/109 dated 09.09.2022 and subsequent communications regarding draft interim detailed procedure for estimation of reserve requirements as per the Regulation 6 (1) of the CERC (Ancillary Services) Regulations 2022 for approval of the Commission.

2. The matter has been considered in the Commission and have been approved by the Commission as the Annexure enclosed.
3. Wide publicity to be given to the above Procedures for information and compliance of all concerned.

Yours sincerely


(Harpreet Singh Pruthi)

Encl: As above.



Power System Operation Corporation Ltd.
Nodal Agency - National Load Despatch Centre (NLDC)

Detailed Procedure
For
Estimation of the Requirement of
Secondary Reserve Ancillary Service (SRAS)
and
Tertiary Reserve Ancillary Service (TRAS)
at Regional Level

*Prepared in Compliance to Central Electricity Regulatory Commission
(Ancillary Services) Regulations, 2022*

1.0 Preamble

- 1.1 Indian grid has met a demand over 207 GW through both inter-state and intra-state resources.
- 1.2 Every entity shall undertake all appropriate measures to maintain its drawal/injection as per schedule. Each control area has to follow certain Frequency Response Performance (FRP) criteria, as may be specified in Indian Electricity Grid Code (IEGC), in order to maintain frequency within the IEGC stipulated band under normal operating conditions.
- 1.3 The objective of Ancillary Services in Indian power system is to maintain the grid frequency close to 50 Hz, restoration of the grid frequency within the allowable band as specified in the IEGC and for relieving congestion in the transmission network, to ensure smooth operation of the power system, and safety and security of the grid.
- 1.4 Adequate reserves are required to be maintained in a distributed manner with both the regional entities at the regional level and at the State level for each state control area as per the IEGC or the State Grid Code as the case may be.
- 1.5 The Nodal Agency i.e. National Load Despatch Centre (NLDC) shall, in coordination with Regional Load Despatch Centres (RLDCs) and State Load Despatch Centres (SLDCs), estimate the quantum of requirement of Secondary Reserves for SRAS and Tertiary Reserves for TRAS at the regional level after factoring in the reserves for each state control area, for such period and based on such methodology as specified in the IEGC and publish the same on its website.
- 1.6 There would be assessment of reserves on year ahead basis, quarter ahead basis week-ahead basis, day ahead basis and intra-day basis.
- 1.7 This procedure provides an interim methodology for estimation of reserves in accordance with Regulation 6(1) of the Central Electricity Regulatory Commission

(CERC) (Ancillary Services) Regulations, 2022, hereinafter referred to as the "AS Regulations".

- 1.8 Nodal Agency would consider the 99 Percentile of the Area Control Error of the respective control area as the basis for the assessment of reserves for SRAS and TRAS.
- 1.9 All the words and expressions used in the Procedure shall have the same meaning as assigned to them in various CERC Regulations.

2.0 Objective

- 2.1 The objective of this procedure is to lay down the roles of various entities and methodology for estimation of quantum of reserves for SRAS and TRAS to be followed by the Nodal Agency i.e. NLDC in coordination with RLDCs and SLDCs.

3.0 Definitions

- 3.1 '**Reference contingency**' means the maximum positive power deviation occurring instantaneously between generation and demand and considered for dimensioning of reserves.

4.0 Scope

- 4.1 The procedure shall be applicable to all entities as provided in the AS regulations, 2022.

5.0 Roles of NLDC (Nodal Agency), RLDCs and SLDCs

- 5.1 Nodal Agency i.e. NLDC shall, in coordination with RLDCs and SLDCs, estimate the quantum of requirement of SRAS & TRAS on year ahead basis, quarter ahead basis, week-ahead basis, day ahead basis and real-time basis as per the methodology specified in subsequent sections.
- 5.2 SLDCs shall furnish data in the stipulated formats to the Nodal Agency for estimation of the quantum of requirement of SRAS & TRAS.
- 5.3 SLDC shall maintain reserves as estimated by Nodal Agency or as per the estimation carried out by the SLDC in accordance with the IEGC or State Grid Code, as the case may be.

6.0 Reserves in Indian Power System

6.1 There shall be different types of reserves, as specified in the IEGC and AS regulations, such as primary, secondary and tertiary for the purpose of frequency control and regulating Area Control Error. The reserves shall be deployed by each control area as per the IEGC and the applicable AS regulations:

6.1.1 Provision for primary response shall be mandatory.

6.1.2 Secondary reserves shall be deployed through a regulated mechanism.

6.1.3 Tertiary reserves shall be procured through the market and deployed

6.2 The deployment of reserves is broadly distinguished on the basis of the time of initiation and duration of response as tabulated in Table-1 below:

Reserve	Start of activation	Full Availability/ deployment	Ability to sustain the full deployment
Primary Response*	Instantaneous as soon as frequency crosses the dead band	<= 30 sec	Up to 5 min
Secondary control Reserve	>= 30 sec	<= 15 Min	Up to 30 min or till replaced by Tertiary Reserves
Tertiary control Reserve	Usually > 15 Min to 1 hour		

Table 1: Reserves and their activation

7.0 Area Control Error (ACE)

7.1 "Area Control Error" or "ACE" means the instantaneous difference between a control area's net actual interchange and net scheduled interchange, taking into account the effects of frequency bias and correction of measurement errors.

7.2 The Area Control Error (ACE) for each control area would be calculated at all the load despatch centres based on telemetered values and external inputs as per the below formula:

$$\text{ACE} = (I_a - I_s) - 10 * B_f * (F_a - F_s) + \text{Offset}$$

Detailed Procedure for Estimation of the Requirement of Secondary Reserve Ancillary Service (SRAS) and Tertiary Reserve Ancillary Service (TRAS) at Regional Level

Ia = Actual net interchange in MW (positive value for export)

Is = Scheduled net interchange in MW (positive value for export)

Bf = Frequency Bias Coefficient in MW/0.1 Hz (negative value)

Fa = Actual system frequency in Hz

Fs = Schedule system frequency in Hz (default 50 Hz)

Offset = Provision for compensating errors such as measurement error; default value zero.

7.3 The detailed methodology to be followed by Nodal Agency for calculation and monitoring of Area Control Error (ACE) is attached at **Annexure – 1**. The ACE shall be worked out for each state and region. Post calculation of the ACE, the outliers would be removed using appropriate statistical techniques.

7.4 ACE is 'positive' means that the control area has surplus generation and the control area's internal generation has to be backed down. ACE is 'negative' means the control area is in deficit and the control area's internal generation has to be increased. All the frequency control interventions shall be in the direction to drive ACE towards zero.

8.0 Estimation of Reserves

8.1 CERC vide its order dated 13th October, 2015 in the matter of Petition no. 11/SM/2015 envisaged loss of complete power station as a credible contingency for maintaining primary reserve. The most credible reference contingency for maintaining primary reserve, presently considered in the Indian power system, is the outage of the largest power plant or sudden load throw-off of 4500 MW.

8.2 The data for assessment of the reserves capacity requirement for SRAS and TRAS shall be furnished to the Nodal Agency by respective SLDCs pertaining to their state control areas as per following timelines.

- 8.2.1 Year Ahead Basis – For reserve estimation for the next financial year (FY+1), the data for the previous calendar year shall be furnished by 15th January of the current financial year (FY) **(Format – RAS1)**.
(Illustration: If the assessment is being carried out for FY 2022-23, the data for the period 1st Jan 2021 to 31st December 2021 has to be provided by 15th January, 2022)
- 8.2.2 Quarter Ahead Basis – For reserve estimation of the next quarter (Q+1) , the data for the similar quarter (Q-3) of the previous year shall be furnished by 15th day of the first month of current quarter (Q)**(Format – RAS2)**
(Illustration: If the assessment is being carried out for Q2 of FY 2022-23 i.e. 01st July – 30th September, 2022, the data for Q2 of FY 2021-22 i.e. 01st July – 30th September 2021 has to be provided by First Month of Q1 of FY 2022-23 i.e. 15th April, 2022)
- 8.3 In case of non-availability of data from SLDCs as mentioned above, the data available at RLDCs/Nodal Agency shall be used to estimate the quantum of reserves requirement.
- 8.4 Week-ahead, Day-Ahead and Real-Time Basis – Nodal Agency would use the data available with RLDCs/Nodal Agency.
- 8.4.1 For weekly reserves requirement computation for the next week (W+1), data for the past four weeks (W-1, W-2, W-3, W-4) and same week (W+1) of the last year shall be used.
- 8.4.2 For the day ahead reserve estimation, last seven days data shall be used.
- 8.4.3 For real time reserve estimation, the estimated day ahead reserve requirement, availability of reserves on day ahead basis, real time system conditions, load/RE forecast, load generation balance, weather, contingencies, congestion and other related parameters shall be used.

Secondary Reserves

- 8.5 The estimation of secondary reserve capacity requirement, on regional basis and state basis, factoring in the reserves for each state control area, shall be carried out by Nodal Agency as per the following methodology:
- 8.5.1 The positive (Up Reserve) and negative (Down Reserve) secondary reserve capacity requirement on regional basis would be computed as 99 percentile of negative and positive ACE respectively of that region for year ahead, quarter ahead and week ahead.
 - 8.5.2 The 99 percentile of the positive and negative ACE of each state control shall be computed and aggregated at regional level. This shall be scaled using 99 percentiles of the regional ACE to factor diversity at regional level. The scaled values of 99 percentile of the state ACE shall be used to arrive at the reserve requirement at Inter-state and Intra-state levels.
 - 8.5.3 The drawl by the respective state and its internal-generation at the time of peak demand during the period under consideration shall be used for apportionment of the reserve requirement. The intra state reserves shall be in proportion to the contribution of internal generation at the time peak demand. The Inter-state reserves shall be in proportion to the drawl from the grid at the time of peak demand.
 - 8.5.4 The state level requirement shall be aggregated to arrive at the regional and all India reserve requirement.
 - 8.5.5 If any state control area has net injection in the concerned period, then, entire reserve margin is to be kept within the state control area.
- 8.6 The all-India total of positive (and negative) secondary reserves capacity requirement on regional basis shall be equal to the reference contingency or secondary reserve capacity requirement as computed above, whichever is higher. If the all-India reserve requirement, computed using 99 percentile of ACE, is less than the reference contingency such additional reserves shall be considered in the regional requirement.

Tertiary Reserves

- 8.7 The estimated quantum of tertiary reserve requirement at regional level would be considered equal to the secondary reserve requirement at regional level as computed above.
- 8.8 The estimated quantum of tertiary reserve requirement at state level would be considered equal to the sum of secondary reserve requirement at state level and 50 % of the largest unit size in the respective state control area.

Day-Ahead Assessment of Requirement of Reserves for SRAS and TRAS

- 8.9 The Nodal Agency shall use the last 7 days data for ACE and the methodology outlined above for assessment of the reserve requirement for SRAS and TRAS on day-ahead.
- 8.10 The Nodal Agency would consider the most credible contingency along with generation on-bar at a single generation complex/zone to arrive at the minimum quantum for tertiary reserves to be maintained on a day-ahead basis. This quantum may vary depending on the despatch scenario and additional requirement would be included, if any, as per the grid conditions.

Real Time Assessment of Requirement of Reserves for SRAS and TRAS

- 8.11 For real time reserve estimation, the estimated day ahead reserve requirement, availability of reserves on day ahead basis, real time system conditions, load/RE forecast, load generation balance, weather, contingencies, congestion, and other related parameters shall be used.

9.0 Information Dissemination

- 9.1 The requirement of SRAS and TRAS reserves on year ahead, quarterly and week-ahead basis would be displayed and updated on the Nodal Agency website.
- 9.2 The reference contingency shall be declared by Nodal Agency by 25th January before the start of each financial year (**Format – RAS3**). The review of reference contingency may be done by the Nodal Agency any time after the declaration.

Accordingly, the figures of reference contingency would be revised and updated on the Nodal Agency website.

(Illustration: The reference contingency for financial year 2023-24 would be declared by 25th January, 2023)

- 9.3 The assessment of the reserves capacity requirement for SRAS and TRAS on Year Ahead Basis would be declared by Nodal Agency by 25th January of the current year **(Format – RAS4)**

(Illustration: The reserve requirement for SRAS and TRAS in financial year 2023-24 would be declared by 25th January, 2023)

- 9.4 The assessment of the reserves capacity requirement for SRAS and TRAS on Quarterly Basis would be declared by Nodal Agency by last day of the first month of the current quarter **(Format – RAS5)**

(Illustration: The reserve requirement for SRAS and TRAS in quarter July – September, 2022 would be declared by 30th April, 2022)

- 9.5 The assessment of the reserve capacity requirement for SRAS and TRAS for the succeeding week would be declared by Nodal Agency by Thursday of the current week **(Format – RAS6)**

(Illustration: The reserve requirement for SRAS and TRAS in Week-10 of FY 2022-23 would be declared by Thursday of Week-9 of FY 2022-23)

- 9.6 The summary of reserve requirement on year-ahead, quarter-ahead and week-ahead would be published on Nodal Agency website **(Format – RAS7)**.

- 9.7 The status of data received by the nodal agency from various sources and static data such as peak demand of the state, internal generation, frequency bias etc. shall also be published on the nodal agency website.

10.0 Revision of the procedures

Notwithstanding anything contained in this Procedure, NLDC/RLDCs may take appropriate decisions in the interest of System Operation. Such decisions shall be taken under intimation to CERC and the procedure shall be modified/amended with the approval of the CERC, as necessary.

Data for Estimation of Year Ahead Reserves

Following Data is to be provided by each state control area

1. Assessment of reserves for the FY: 01.04.yyyy to 31.03.yyyy
2. Name of the state:
3. Data for the calendar: 01.01.yyyy to 31.12.yyyy
4. Data furnished (please tick the data submitted):
 - a. Actual interchange of the State (10 seconds resolution), (Number of samples = $365*24*60*6 = 3153600$ nos.) in excel format
 - b. Frequency Response Characteristics of the State for the events posted on NLDC website (<https://posoco.in/frc/>)
 - c. Peak Demand met
 - d. Intra-State Generation (other than ISGS) at the time of peak demand

Actual interchange of the State (10 seconds resolution) for calendar: 01.01.yyyy to 31.12.yyyy	
Date & Time (DD-MMM-YY HH:MM:SS)	Actual interchange of the State (MW)
01-jan-2021 00:00:10	452
01-jan-2021 00:00:20	456
01-jan-2021 00:00:30	461
.....	
.....	
31-Dec-2021 23:59:50	498

Frequency Response Characteristics of the State for calendar: 01.01.yyyy to 31.12.yyyy (In case State has difficulty in computation of FRC, it may seek assistance from respective RLDC)	
Event Details	Frequency Response Characteristics (MW/Hz)
Events 1:	800
Event 2:	815
Event 3:	756

Peak Demand and Intra-State Generation of the State for calendar: 01.01.yyyy to 31.12.yyyy		
State/UT	Peak Demand met (MW)	Intra-State Generation (other than ISGS) at the time of peak demand (MW)
.....		

Detailed Procedure for Estimation of the Requirement of Secondary Reserve Ancillary Service (SRAS) and Tertiary Reserve Ancillary Service (TRAS) at Regional Level

Data for Estimation of Quarter Ahead Reserves

Following Data is to be provided by each state control area

1. Assessment of reserves for the FY: 01.mm.yyyy to 31.mm.yyyy
2. Name of the state:
3. Data for the Quarter: 01.mm.yyyy to 31.mm.yyyy
4. Data furnished (please tick the data submitted):
 - a. Actual interchange of the State (10 seconds resolution), (Number of samples = $90/91/92*24*60*6 = 777600/786240/794880$ nos.) in excel format
 - b. Frequency Response Characteristics of the State for the events posted on NLDC website (<https://posoco.in/frc/>)
 - c. Peak Demand met
 - d. Intra-State Generation (other than ISGS) at the time of peak demand

Actual interchange of the State (10 seconds resolution) for the Quarter: 01.mm.yyyy to 31.mm.yyyy	
Date & Time (DD-MMM-YY HH:MM:SS)	Actual interchange of the State (MW)
01-Apr-2021 00:00:10	452
01-Apr-2021 00:00:20	456
01-Apr-2021 00:00:30	461
.....	
.....	
31-June-2021 23:59:50	498

Frequency Response Characteristics of the State for the Quarter: 01.mm.yyyy to 31.mm.yyyy (In case SLDC has difficulty in computation of FRC, it may seek assistance from respective RLDC)	
Event Details	Frequency Response Characteristics (MW/Hz)
Events 1:	800
Event 2:	815

Peak Demand and Intra-State Generation of the State for Quarter: 01.mm.yyyy to 31.mm.yyyy		
State/UT	Peak Demand met (MW)	Intra-State Generation (other than ISGS) at the time of peak demand (MW)
.....		

Reference contingency for Indian Power System

Date: 25 January 2023	Revision No.	
Applicable for FY 2023-24		
Reference Contingency for generation loss (MW)	4500	
Reference Contingency for load loss (MW)	4500	

Format RAS4

SRAS and TRAS Reserve requirement for year 2022-23																	
State/UT	Actual 99 Percentile Negative ACE (MW)	Actual 99 Percentile Positive ACE (MW)	Scaled 99 Percentile Negative ACE (MW) (a)	Scaled 99 Percentile Positive ACE (MW) (b)	Max. Demand met (c)	Internal Gen. at the time of max demand (d)	Drawl from ISTS (e=c-d)	State Internal Generation/ State Maximum Demand (f=d/c)	State drawl from ISTS/ State Maximum Demand (g=e/c)	Secondary Reserves in ISGS (h=a*g)	Secondary Reserves at Regional Level (sum of reserves in all states of the region as given in "h")	Secondary Reserves within state (i=a*f)	Tertiary Reserves in ISGS (j = h)	Tertiary Reserves within state (k = i)	Largest Unit Size of internal generation (l)	Total Tertiary Reserves within state (m=k + 0.5*l)	
Punjab	307	505	125	310	13431	6014	7417	0.45	0.55	69	725	56	69	56	700	406	
Haryana	411	443	167	272	12120	2953	9167	0.24	0.76	126		41	126	41	660	371	
Rajasthan	730	735	296	451	15696	9701	5995	0.62	0.38	113		183	113	183	660	513	
Delhi	156	273	63	168	7305	645	6660	0.09	0.91	58		6	58	6	216	114	
Uttar Pradesh	658	847	267	520	24795	12302	12493	0.50	0.50	135		133	135	133	660	463	
Uttarakhand	200	198	81	122	2318	812	1506	0.35	0.65	53		28	53	28	76	66	
UT Chandigarh	45	76	18	47	426	0	426	0.00	1.00	18		0	18	0	0	0	
Himachal Pradesh	165	173	67	106	1955	675	1280	0.35	0.65	44		23	44	23	100	73	
UT Jammu & Kashmir	296	260	120	160	2743	240	2503	0.09	0.91	110		11	110	11	150	86	
NR state Sum	2968	3510	1205	2154													2091
Northern Region	1205	2154															
West Bengal	319	336	237	201	9316	6800	2516	0.73	0.27	64	522	173	64	173	500	423	
Bihar	364	381	270	228	6868	400	6468	0.06	0.94	255		16	255	16	250	141	
Odisha	281	336	209	201	6008	3903	2105	0.65	0.35	73		136	73	136	600	436	
Jharkhand	154	164	114	98	1718	394	1324	0.23	0.77	88		26	88	26	210	131	
DVC	272	273	202	163	3487	5638	-2151	1.62	-0.62	0		202	0	202	600	502	
Sikkim	57	48	42	29	132	0	132	0.00	1.00	42		0	42	0	0	0	
ER state Sum	1447	1538	1075	921													1633
Eastern Region	1075	921															
Maharashtra	547	625	424	404	25644	16595	9049	0.65	0.35	149	829	274	149	274	660	604	
Gujarat	657	594	509	384	19431	10416	9015	0.54	0.46	236		273	236	273	800	673	
Madhya Pradesh	488	607	378	392	15917	5991	9926	0.38	0.62	236		142	236	142	660	472	
Chhattisgarh	232	232	180	150	4870	2172	2698	0.45	0.55	100		80	100	80	500	330	
UT Dadra Nagar Haveli	56	33	43	21	888	0	888	0.00	1.00	43		0	43	0	0	0	
UT Daman Diu	39	22	30	14	369	0	369	0.00	1.00	30		0	30	0	0	0	
Goa	45	41	35	26	698	0	698	0.00	1.00	35		0	35	0	0	0	
WR States Sum	2064	2154	1598	1392													2079
Western Region	1598	1392															
Andhra Pradesh	571	442	302	265	11472	5319	6153	0.46	0.54	162		620	140	162	140	800	540
Tamil Nadu	609	641	322	384	16846	7624	9222	0.45	0.55	176	146		176	146	600	446	
Karnataka	587	535	311	320	14367	9354	5013	0.65	0.35	108	202		108	202	800	602	
Kerala	183	191	97	114	4284	1519	2765	0.35	0.65	62	34		62	34	130	99	
UT Puducherry	35	60	19	36	452	0	452	0.00	1.00	19	0		19	0	0	0	
Telangana	391	418	207	250	13688	7561	6127	0.55	0.45	93	114		93	114	800	514	
SR State Sum	2376	2287	1257	1369													2202
Southern Region	1257	1369															
Assam	111	111	72	87	2132	340	1792	0.16	0.84	60	154		11	60	11	50	36
Meghalaya	41	39	27	31	391	114	277	0.29	0.71	19			8	19	8	42	29
Tripura	59	60	38	47	327	172	155	0.53	0.47	18		20	18	20	21	31	
Manipur	25	26	16	20	244	0	244	0.00	1.00	16		0	16	0	0	0	
Mizoram	16	23	10	18	144	54	90	0.38	0.63	6		4	6	4	6	7	
Nagaland	20	30	13	24	153	14	139	0.09	0.91	12		1	12	1	8	5	
Arunachal Pradesh	34	42	22	33	162	0	162	0.00	1.00	22		0	22	0	0	0	
NER State Sum	306	331	198	260													108
North-Eastern Region	198	260															
All India	5333	6096	5333	6096										2850			8112
Total Tertiary Reserves Requirement in India													10963				

***Please Note: Based on Actual Data for Illustration Purpose only**

Detailed Procedure for Estimation of the Requirement of Secondary Reserve Ancillary Service (SRAS) and Tertiary Reserve Ancillary Service (TRAS) at Regional Level

Format RAS5

SRAS and TRAS Reserve requirement for Quarter 1 of year 2022-23																
State/UT	Actual 99 Percentile Negative ACE (MW)	Actual 99 Percentile Positive ACE (MW)	Scaled 99 Percentile Negative ACE (MW) (a)	Scaled 99 Percentile Positive ACE (MW) (b)	Max. Demand met (c)	Internal Gen. at the time of max demand (d)	Draw from ISTS (e=c-d)	State Internal Generation/ State Maximum Demand (f=d/c)	ISTS/ State Maximum Demand (g=e/c)	Secondary Reserves in ISGS (h=a*f)	Secondary Reserves at Regional Level (sum of reserves in all states of the region as given in "h")	Secondary Reserves within state (i=a*f)	Tertiary Reserves in ISGS (j = h)	Tertiary Reserves within state (k = i)	Largest Unit Size of internal generation (l)	Total Tertiary Reserves within state (m=k + 0.5*l)
Punjab	326	600	86	356	24494	22319	2175	0.91	0.09	8	406	78	8	78	700	428
Haryana	458	629	120	373	11484	2943	8541	0.26	0.74	90		31	90	31	660	361
Rajasthan	761	856	200	508	13061	7497	5564	0.57	0.43	85		115	85	115	660	445
Delhi	156	292	41	173	6943	641	6302	0.09	0.91	37		4	37	4	216	112
Uttar Pradesh	761	1062	200	630	27587	21518	6069	0.78	0.22	44		156	44	156	660	486
Uttarakhand	197	250	52	148	2169	829	1340	0.38	0.62	32		20	32	20	76	58
UT Chandigarh	39	60	10	36	381	0	381	0.00	1.00	10		0	10	0	0	0
Himachal Pradesh	163	174	43	103	1644	587	1057	0.36	0.64	28		15	28	15	100	65
UT Jammu & Kashmir	329	305	86	181	2626	428	2198	0.16	0.84	72		14	72	14	150	89
NR state Sum	3190	4228	838	2509												
Northern Region	838	2509														
West Bengal	365	423	326	221	9068	6569	2499	0.72	0.28	90	734	236	90	236	500	486
Bihar	426	472	380	246	6045	387	5658	0.06	0.94	356		24	356	24	250	149
Odisha	284	369	254	192	5771	3367	2404	0.58	0.42	106		148	106	148	600	448
Jharkhand	172	197	153	103	1636	217	1419	0.13	0.87	133		20	133	20	210	125
DVC	256	286	228	149	3421	5603	-2182	1.64	-0.64	0		228	0	228	600	528
Sikkim	56	60	50	31	96	0	96	0.00	1.00	50		0	50	0	0	0
ER state Sum	1558	1807	1391	943												
Eastern Region	1391	943														
Maharashtra	594	580	591	440	26053	17340	8713	0.67	0.33	198	853	394	198	394	660	724
Gujarat	660	627	656	476	19265	13356	5909	0.69	0.31	201		455	201	455	800	855
Madhya Pradesh	433	659	431	500	11219	5790	5429	0.52	0.48	209		223	209	223	660	553
Chhattisgarh	228	261	227	198	4820	2324	2496	0.48	0.52	117		109	117	109	500	359
UT Dadra Nagar Haveli	53	34	53	26	860	0	860	0.00	1.00	53		0	53	0	0	0
UT Daman Diu	30	23	30	17	344	0	344	0.00	1.00	30		0	30	0	0	0
Goa	46	48	46	36	606	0	606	0.00	1.00	46		0	46	0	0	0
WR States Sum	2044	2232	2034	1695												
Western Region	2034	1695														
Andhra Pradesh	697	524	418	355	11573	5416	6157	0.47	0.53	223	771	196	223	196	800	596
Tamil Nadu	594	636	357	431	17248	8017	9231	0.46	0.54	191		166	191	166	600	466
Karnataka	587	488	352	330	14194	8712	5482	0.61	0.39	136		216	136	216	800	616
Kerala	180	178	108	120	4380	1664	2716	0.38	0.62	67		41	67	41	130	106
UT Puducherry	33	56	20	38	457	0	457	0.00	1.00	20		0	20	0	0	0
Telangana	416	428	250	290	13559	6227	7332	0.46	0.54	135		115	135	115	800	515
SR State Sum	2507	2309	1504	1565												
Southern Region	1504	1565														
Assam	127	122	104	96	1974	330	1644	0.17	0.83	87	227	17	87	17	50	42
Meghalaya	42	42	34	33	354	0	354	0.00	1.00	34		0	34	0	42	21
Tripura	78	60	64	47	336	176	160	0.52	0.48	31		34	31	34	21	44
Manipur	24	23	19	18	226	0	226	0.00	1.00	19		0	19	0	0	0
Mizoram	16	19	13	15	130	0	130	0.00	1.00	13		0	13	0	6	3
Nagaland	18	21	15	17	149	0	149	0.00	1.00	15		0	15	0	8	4
Arunachal Pradesh	35	51	28	40	145	0	145	0.00	1.00	28		0	28	0	0	0
NER State Sum	340	337	278	266												
North-Eastern Region	278	266														
All India	6046	6977	6046	6977									2992			8684
Total Tertiary Reserves Requirement in India												11676				

***Please Note: Based on Actual Data for Illustration Purpose only**

Detailed Procedure for Estimation of the Requirement of Secondary Reserve Ancillary Service (SRAS) and Tertiary Reserve Ancillary Service (TRAS) at Regional Level

Format RAS6

Week-Ahead SRAS and TRAS Reserve requirement for Week 04 April to 10 April 2022																	
State/UT	Actual 99 Percentile Negative ACE (MW)	Actual 99 Percentile Positive ACE (MW)	Scaled 99 Percentile Negative ACE (MW) (a)	Scaled 99 Percentile Positive ACE (MW) (b)	Max. Demand (c)	Internal Gen. at the time of max demand (d)	Drawl from ISTS (e=c-d)	State Internal Generation/ State Maximum Demand (f=d/c)	State drawl from ISTS/ State Maximum Demand (g=e/c)	Secondary Reserves in ISGS (h=a*g)	Secondary Reserves at Regional Level (sum of reserves in all states of the region as given in 'h')	Secondary Reserves within state (i=a*f)	Tertiary Reserves in ISGS (j = h)	Tertiary Reserves within state (k = i)	Largest Unit Size of Internal generation (l)	Total Tertiary Reserves within state (m=k + 0.5*l)	
Punjab	287	383	94	219	8631	4460	4171	0.52	0.48	46	591	49	46	49	700	399	
Haryana	434	360	143	206	7825	2294	5531	0.29	0.71	101		42	101	42	660	372	
Rajasthan	641	734	210	420	15992	9411	6581	0.59	0.41	87		124	87	124	660	454	
Delhi	159	227	52	130	4097	535	3562	0.13	0.87	45		7	45	7	216	115	
Uttar Pradesh	644	806	211	462	20843	8955	11888	0.43	0.57	121		91	121	91	660	421	
Uttarakhand	205	210	67	120	2152	770	1382	0.36	0.64	43		24	43	24	76	62	
UT Chandigarh	27	92	9	53	215	0	215	0.00	1.00	9		0	9	0	0	0	
Himachal Pradesh	159	158	52	91	1890	593	1297	0.31	0.69	36		16	36	16	100	66	
UT Jammu & Kashmir	346	268	114	154	3004	228	2776	0.08	0.92	105		9	105	9	150	84	
NR state Sum	2901	3239	952	1856													1972
Northern Region	952	1856															
West Bengal	272	329	209	280	8586	6775	1811	0.79	0.21	44	447	165	44	165	500	415	
Bihar	285	297	219	252	5769	319	5450	0.06	0.94	206		12	206	12	250	137	
Odisha	271	335	208	284	5597	3260	2337	0.58	0.42	87		121	87	121	600	421	
Jharkhand	158	134	121	114	1583	409	1174	0.26	0.74	90		31	90	31	210	136	
DVC	224	241	172	204	3563	5295	-1732	1.49	-0.49	0		172	0	172	600	472	
Sikkim	26	47	20	40	120	0	120	0.00	1.00	20		0	20	0	0	0	
ER state Sum	1235	1383	948	1175													1581
Eastern Region	948	1175															
Maharashtra	696	546	454	281	33111	24101	9010	0.73	0.27	123	791	330	123	330	660	660	
Gujarat	654	649	426	334	18900	9450	9450	0.50	0.50	213		213	213	213	800	613	
Madhya Pradesh	487	619	318	319	15102	4487	10615	0.30	0.70	223		94	223	94	660	424	
Chhattisgarh	215	208	140	107	5132	2392	2740	0.47	0.53	75		65	75	65	500	315	
UT Dadra Nagar Haveli	80	35	52	18	910	0	910	0.00	1.00	52		0	52	0	0	0	
UT Daman Diu	66	28	43	14	364	0	364	0.00	1.00	43		0	43	0	0	0	
Goa	95	47	62	24	596	0	596	0.00	1.00	62		0	62	0	0	0	
WR States Sum	2293	2132	1494	1097													2013
Western Region	1494	1097															
Andhra Pradesh	588	380	446	225	12028	5875	6153	0.49	0.51	228	993	218	228	218	800	618	
Tamil Nadu	615	636	467	377	16766	6769	9997	0.40	0.60	278		189	278	189	600	489	
Karnataka	681	472	517	280	14859	9137	5722	0.61	0.39	199		318	199	318	800	718	
Kerala	167	173	126	103	4405	1625	2780	0.37	0.63	80		47	80	47	130	112	
UT Puducherry	31	57	24	34	440	0	440	0.00	1.00	24		0	24	0	0	0	
Telangana	491	451	373	267	13882	7055	6827	0.51	0.49	183		189	183	189	800	589	
SR State Sum	2573	2169	1953	1285													2525
Southern Region	1953	1285															
Assam	103	100	64	102	1847	213	1634	0.12	0.88	56	147	7	56	7	50	32	
Meghalaya	44	34	27	34	372	86	286	0.23	0.77	21		6	21	6	42	27	
Tripura	61	54	38	54	292	150	142	0.51	0.49	18		19	18	19	21	30	
Manipur	21	25	13	25	225	0	225	0.00	1.00	13		0	13	0	0	0	
Mizoram	14	21	9	21	124	0	124	0.00	1.00	9		0	9	0	6	3	
Nagaland	18	22	11	22	164	0	164	0.00	1.00	11		0	11	0	8	4	
Arunachal Pradesh	30	50	19	51	192	0	192	0.00	1.00	19		0	19	0	0	0	
NER State Sum	292	306	180	309													97
North-Eastern Region	180	309															
All India	5527	5722	5527	5722										2969			8188
Total Tertiary Reserves Requirement in India												11157					

***Please Note: Based on Actual Data for Illustration Purpose only**

Detailed Procedure for Estimation of the Requirement of Secondary Reserve Ancillary Service (SRAS) and Tertiary Reserve Ancillary Service (TRAS) at Regional Level

Summary of Reserve Requirement

State/UT	Year-Ahead						Quarter-Ahead						Week-Ahead					
	Secondary Reserves			Tertiary Reserves			Secondary Reserves			Tertiary Reserves			Secondary Reserves			Tertiary Reserves		
	Within in ISGS	Within state	Total	Within in ISGS	Within state	Total	Within in ISGS	Within state	Total	Within in ISGS	Within state	Total	Within in ISGS	Within state	Total	Within in ISGS	Within state	Total
Punjab	69	56	125	69	406	475	8	78	86	8	428	436	46	49	94	46	399	444
Haryana	126	41	167	126	371	497	90	31	120	90	361	450	101	42	143	101	372	473
Rajasthan	113	183	296	113	513	626	85	115	200	85	445	530	87	124	210	87	454	540
Delhi	58	6	63	58	114	171	37	4	41	37	112	149	45	7	52	45	115	160
Uttar Pradesh	135	133	267	135	463	597	44	156	200	44	486	530	121	91	211	121	421	541
Uttarakhand	53	28	81	53	66	119	32	20	52	32	58	90	43	24	67	43	62	105
UT Chandigarh	18	0	18	18	0	18	10	0	10	10	0	10	9	0	9	9	0	9
Himachal Pradesh	44	23	67	44	73	117	28	15	43	28	65	93	36	16	52	36	66	102
UT Jammu & Kashmir	110	11	120	110	86	195	72	14	86	72	89	161	105	9	114	105	84	189
West Bengal	64	173	237	64	423	487	90	236	326	90	486	576	44	165	209	44	415	459
Bihar	255	16	270	255	141	395	356	24	380	356	149	505	206	12	219	206	137	344
Odisha	73	136	209	73	436	509	106	148	254	106	448	554	87	121	208	87	421	508
Jharkhand	88	26	114	88	131	219	133	20	153	133	125	258	90	31	121	90	136	226
DVC	0	202	202	0	502	502	0	228	228	0	528	528	0	172	172	0	472	472
Sikkim	42	0	42	42	0	42	50	0	50	50	0	50	20	0	20	20	0	20
Maharashtra	149	274	424	149	604	754	198	394	591	198	724	921	123	330	454	123	660	784
Gujarat	236	273	509	236	673	909	201	455	656	201	855	1056	213	213	426	213	613	826
Madhya Pradesh	236	142	378	236	472	708	209	223	431	209	553	761	223	94	318	223	424	648
Chhattisgarh	100	80	180	100	330	430	117	109	227	117	359	477	75	65	140	75	315	390
UT Dadra Nagar Haveli	43	0	43	43	0	43	53	0	53	53	0	53	52	0	52	52	0	52
UT Daman Diu	30	0	30	30	0	30	30	0	30	30	0	30	43	0	43	43	0	43
Goa	35	0	35	35	0	35	46	0	46	46	0	46	62	0	62	62	0	62
Andhra Pradesh	162	140	302	162	540	702	223	196	418	223	596	818	228	218	446	228	618	846
Tamil Nadu	176	146	322	176	446	622	191	166	357	191	466	657	278	189	467	278	489	767
Karnataka	108	202	311	108	602	711	136	216	352	136	616	752	199	318	517	199	718	917
Kerala	62	34	97	62	99	162	67	41	108	67	106	173	80	47	126	80	112	191
UT Puducherry	19	0	19	19	0	19	20	0	20	20	0	20	24	0	24	24	0	24
Telangana	93	114	207	93	514	607	135	115	250	135	515	650	183	189	373	183	589	773
Assam	60	11	72	60	36	97	87	17	104	87	42	129	56	7	64	56	32	89
Meghalaya	19	8	27	19	29	48	34	0	34	34	21	55	21	6	27	21	27	48
Tripura	18	20	38	18	31	49	31	34	64	31	44	75	18	19	38	18	30	48
Manipur	16	0	16	16	0	16	19	0	19	19	0	19	13	0	13	13	0	13
Mizoram	6	4	10	6	7	13	13	0	13	13	3	16	9	0	9	9	3	12
Nagaland	12	1	13	12	5	17	15	0	15	15	4	19	11	0	11	11	4	15
Arunachal Pradesh	22	0	22	22	0	22	28	0	28	28	0	28	19	0	19	19	0	19
Region-wise and All-India																		
Northern Region	725	480	1205	725	2091	2816	406	433	838	406	2044	2449	591	361	952	591	1972	2563
Western Region	829	769	1598	829	2079	2908	853	1181	2034	853	2491	3344	791	703	1494	791	2013	2804
Southern Region	620	637	1257	620	2202	2822	771	733	1504	771	2298	3069	993	960	1953	993	2525	3518
Eastern Region	522	553	1075	522	1633	2155	734	657	1391	734	1737	2471	447	501	949	447	1581	2029
North-Eastern Region	154	44	198	154	108	262	227	51	278	227	115	342	147	33	180	147	97	243
All India	2850	2482	5333	2850	8112	10962	2992	3054	6046	2992	8684	11675	2969	2559	5528	2969	8188	11157

***Please Note: Based on Actual Data for Illustration Purpose only**



**National Load Despatch Centre
Power System Operation Corporation Limited**

Guideline for Calculation and Monitoring of Area Control Error

This document provides the detailed guidelines to be uniformly adopted by the NLDC, RLDCs, SLDCs, and REMCs for measurement, calculation, monitoring, and archival of Frequency, Tie-Line Flows, Frequency Bias, Metering Errors, and Area Control Error (ACE). ACE is an important parameter which depicts the health of the power system. This document enables uniform notation for ACE, thereby allowing all the load despatch control rooms pan India to pass on information about this grid security aspect with one another.

Table of the Contents

1. Formula of Area Control Error (ACE)

2. Measurement of Frequency

2.1. Choosing the master list of redundant frequency sources

2.2. Location of redundant frequency sources and host server

2.3. Algorithm for selecting the Primary Frequency Source

3. Measurement of Tie-Line Flows

3.1. Actual Tie-Line Flows

3.2. Scheduled Tie-Line Flows

4. Assessment of Frequency Bias

4.1. Bf value assessment

4.2. Bf update timing

5. Measurement of Metering Errors - OFFSET

6. Calculation of ACE

7. Archival of different parameters

8. Monitoring of ACE and Suggested Corrective Actions

9. Calculating ACE for Regional Entity Control Area

Annexure-I.I: Sample Template for Frequency Response Characteristic Calculation

1. Formula of Area Control Error (ACE)

The Area Control Error (ACE) for each control area¹ would be calculated at all the load despatch centres based on telemetered values and external inputs as per the below formula².

$$\text{ACE} = (I_a - I_s) - 10 * B_f * (F_a - F_s) + \text{Offset}$$

I_a = Actual net interchange in MW (positive value for export)

I_s = Scheduled net interchange in MW (positive value for export)

B_f = Frequency Bias Coefficient in MW/0.1 Hz (negative value)

F_a = Actual system frequency in Hz

F_s = Schedule system frequency in Hz (default 50 Hz)

Offset = Provision for compensating errors such as measurement error; default value zero.

In the above formula, ACE has three components as below.

1. Interchange deviation component (**$I_a - I_s$**)
2. Frequency deviation component - **$10 * B_f * (F_a - F_s)$**
3. Offset or Metering Error

Sign convention adopted for interchange MW values is, positive value for export and negative value for import. B_f is a negative value. System Frequency (F_a) is a positive value, close to the National Reference Frequency³ of 50 Hz.

ACE is positive means that the control area has surplus generation and the control area's internal generation has to be backed down. ACE is negative means the control area is in deficit and the control area's internal generation has to be increased. ACE has to be driven towards zero for better frequency control and grid security.

¹ Control Area means an electrical system bounded by interconnections (tie lines), metering and telemetry which controls its generation and/or load to maintain its interchange schedule with other control areas and contributes to regulation of frequency as specified;

Definition from the Report of the Expert Group: Review of Indian Electricity Grid Code, January 2020. <https://cercind.gov.in/2020/reports/Final%20Report%20dated%2014.1.2020.pdf>

² Formula as given in the Report of the Expert Group: Review of Indian Electricity Grid Code, January 2020.

³ Defined in the Report of the Expert Group: Review of Indian Electricity Grid Code, January 2020.

2. Measurement of Frequency

System frequency is an important input for calculating ACE. Typically, ACE is used for taking generation increase/decrease actions using the below applications

- a. Secondary frequency control through AGC
- b. Tertiary frequency control through TRAS
- c. Monitoring and manual generation rescheduling

All the above three applications operate in the time frame of a few seconds to several minutes. Hence it should suffice that the system frequency signal is captured using a sampling time of a few seconds for calculation of ACE.

Suggested sampling time for frequency: 4 seconds, i.e., take a fresh frequency data point every four seconds.

2.1. Choosing the master list of redundant frequency sources

The frequency signal taken should be free from noise. To ensure the same, the signals from such stations shall be selected as the frequency sources, whose historical data is proven to be at least 99.9% noise-free in the past three months. To identify noise, the frequency data of different stations shall be plotted in a time series graph. The graph should be free from spikes. Choose 10 such stations to act as redundant frequency sources in ACE calculation. This list may be reviewed quarterly.

2.2. Location of redundant frequency sources and host server

For the applications a, b, and c, mentioned above, frequency source from any geographic location should serve the purpose as the time range of interest is in seconds. Typically, in time frame of a few seconds, all the electromagnetic transients and most of the electromechanical transients usually get damped and settled⁴. Hence, stations from different geographic locations can be chosen as redundant frequency sources. Having a mix of at least 10 redundant frequency sources from SCADA and URTDSM (PMU) is advised. Frequency data from URTDSM server are generally imported into SCADA⁵ for the purpose of ACE calculation.

2.3. Algorithm for selecting the Primary Frequency Source

The ACE calculation program can look at the quality tags of all the redundant signals and choose one of the signals as the primary source. The update of the

⁴ For applications b & c, as the dispatches are time block-wise, there is no need of consideration about frequency oscillations. For AGC, oscillations in ACE are further smoothed by the exponential moving average filters and the PI controller (low pass filter) which are typically part of the AGC software. The integration time in AGC is in generally between 10s -120s and hence the electromechanical oscillations and any noise get further damped.

⁵ PMUs are not available on all the tie-lines. Hence calculating ACE is recommended through SCADA.

quality tags happens along with the sampling of the data in the EMS system, as a general practice. In case the quality of the primary frequency source becomes 'suspect', then the next signal with 'good quality tag' shall be selected as the primary frequency source automatically. This logic may be developed into the calculation program gradually, if not immediately.

Algorithm outline:

Initialize Primary Freq= 50 Hz

Initialize K=1

Initialize J=1

Initialize Flag = Good

Call Subroutine-A

Subroutine-A ()

Select the Kth frequency signal in the list as 'primary' and read its quality tag.

If the quality tag is good, set J=1, exit Subroutine-A and GOTO Subroutine-B.

If, J=11, Primary Freq = 50 Hz, exit Subroutine-A and GOTO Subroutine-B.

Else, K=K+1, J=J+1 and Call Subroutine-A.

End Subroutine-A ()

Subroutine-B ()

While Flag = Good

 Read the quality tag of the Kth signal at time t

 If the quality tag is good, t=t0+4s, Flag=Good

 Else Flag = Bad

End While

GOTO Subroutine-A

End Subroutine-B

3. Measurement of Tie-Line Flows

3.1. Actual Tie-Line Flows

Actual tie-line flows shall be sampled every 4 seconds⁶ similar to frequency and shall be used in the ACE calculation. The update of the quality tags happens along with the sampling of the data in the EMS system, as a general practice. Say, the data is acquired only every 12s by the SCADA because of delays⁷, the ACE calculation program shall repeat the data thrice in those 12s. Some Tie-Line flows have the problem of becoming suspect often. Such data should be identified and rectified immediately by following up with site/substation. Efforts shall be made by respective utilities that the clock synchronization across all the stations taken into consideration by the respective LDC and its calibration shall be done once every year in order to ensure the synchronicity of time stamping of the collected data. Every tie-line flow can be obtained from 3 different sources viz.,

- i. Primary Side (choose the Metering End as per IEGC)
- ii. Secondary Side (side other than the Metering End as per IEGC)
- iii. State Estimator output

Primary side data shall be normally used for ACE calculation. In case the quality of the primary side becomes 'suspect', then let the ACE calculation program automatically choose the secondary side. If flow at both the ends goes suspect, use the state estimator output. If the state estimator is not running, replace the suspect data manually with 'last good value', rather than retaining garbage value. Information of manual interventions shall be monitored, carried forward and updated frequently in every shift. Sign convention adopted for interchange MW values is, positive value for export and negative value for import.

Note that all the tie-lines should be accounted for, while calculating the Net Actual Tie-Line Flow (Ia), i.e., algebraic sum of the flows. If any of the tie-lines is non-observable, the data of the same can be replaced with a fixed value as informed by site/substation telephonically to the control room.

3.2. Scheduled Tie-Line Flows

⁶ At NLDC, the tie line flow acquisition delay (around 10s) includes the delay introduced while acquiring data from RLDCs through ICCP, apart from the delay in acquiring tie line data from RTUs to the RLDCs. For other RLDCs/control areas, delay (~ 5s) is mainly introduced in acquiring tie line data from RTUs to the RLDCs. However, this data acquisition timing has to be improved further by all the control areas.

⁷ Higher updation time as well as non-simultaneity can lead to inconsistent frequency response assessment and incorrect ACE calculations. Ideal would be to have PMUs on all inter-regional lines to begin with, followed by all inter-state tie lines.

The Net Scheduled Tie-Line Flow (I_s) of a control area should generally be the output of a scheduling software program, from which the data is imported into SCADA for all the 96-time blocks. ACE is calculated using the net tie-line flow, and path-wise scheduled flows are algebraically added based on direction.

Net Scheduled Tie-Line Flow of the control area can be calculated every time block by adding the algebraic sum of scheduled MW export contracts (from the control area to all the other control areas; positive values) and the scheduled MW import contracts (to the control area from all the other control areas; negative values) and the MW sum of resultant of the virtual entities. In line with the tie-line flow convention, sign convention for TRAS Up regulation is positive, TRAS Down is negative. Note that for ACE calculation, we are interested in the net control area values, and not the path-wise values.

For example, if a particular control area imports 2000 MW from the other control areas through tie-lines, exports 500 MW to the other control areas through tie-lines, TRAS Up of 200 MW is dispatched and SCED Down of 100 MW is dispatched. Then $I_s = -2000 + 500 + 200 - 100 = -1400$ MW for that time block.

Note that the Net Scheduled Tie-Line Flow value shall be always less than the Export Available Transfer Capability (ATC) and greater than the Import ATC value. While calculating ACE, this 15-minute data has to be updated/refreshed every 4 seconds.

4. Assessment of Frequency Bias

The 2017 IEEE Task Force Report⁸ on "Measurement, Monitoring, and Reliability Issues Related to Primary Governing Frequency Response," recommends using Frequency Response Characteristic (FRC) calculated after the power and frequency transients have settled, for the Frequency Bias Coefficient (B_f) used in the ACE equation. A sample size of twenty (20) FRC events has been deemed adequate for estimating the frequency response characteristic to rule out human error. Several other references⁹ also have been studied, which support the IEEE Task Force Report recommendations.

⁸ IEEE Task Force Report. 2017. "Measurement, Monitoring, and Reliability Issues Related to Primary Governing Frequency Response," Technical Report PES-R-24, October. <https://resourcecenter.ieee-pes.org/publications/technical-reports/PESTECRPTGS0001.html>

⁹ J. L. Willems, "Sensitivity Analysis of the Optimum Performance of Conventional Load-Frequency Control," in IEEE Transactions on Power Apparatus and Systems, vol. PAS-93, no. 5, pp. 1287-1291, Sept. 1974, doi: 10.1109/TPAS.1974.293852. <https://ieeexplore.ieee.org/document/4075491>

FRC computation procedure has been clearly provided in the draft IEGC 2020¹⁰. A sample template for FRC assessment is enclosed as Annexure-I.I. FRC shall be computed for every control area for all events involving a sudden 1000 MW or more load/generation loss or a step change in frequency by 0.10 Hz. All these FRC values shall be archived along with date, time and reasons of the event.

4.1. Bf value assessment

In the calculation of ACE, the value of Frequency Bias Coefficient in MW/0.1 Hz (negative value) shall be based on median Frequency Response Characteristic. Median¹¹ value of the past 20 events would be used for updating the FRC. The occurrence of these 20 events is actually expected to cover the entire previous year, thereby subsuming the seasonality aspect of load and generation. The all-India, region-wise and state-wise Bf value, used in the reserve estimation computation, would be provided on the Nodal Agency website as per ***Format RAS8***. Bf value shall be reviewed by the Nodal Agency.

4.2. Bf update timing

The Bias (Bf) value may be reviewed in the ACE calculations at the LDCs, once in every quarter on the 24th day of the month after the completion of the previous quarter. The literature studied and mentioned in the footnotes-6,7 suggests updating the bias values once in a year for practical power systems. However, due to the developing nature of Indian power system, a quarterly update has been suggested. For example, update the Bias (Bf) value on 25th July, after the completion of the quarter April – June. The updated Bf value in SCADA shall also be shared continuously through ICCP bottoms up, from SLDCs to RLDCs, and from RLDCs to NLDC for all the relevant control areas. An offline all India compilation in Excel/DB may be maintained by NLDC for all the control areas. While calculating ACE, this quarterly data has to be updated/refreshed every 4 seconds.

5. Measurement of Metering Errors - OFFSET

NERC, Frequency Response Standard Background Document. November, 2012.

https://www.nerc.com/pa/Stand/Project%20200712%20Frequency%20Response%20DL/Bal-003-1-Background Document-Clean-2013_FILING.pdf

P. Kundur, Power System Stability and Control, Chapter 11, McGraw-Hill, New York, 1994.

¹⁰ Report of the Expert Group: Review of Indian Electricity Grid Code, January 2020. <https://cercind.gov.in/2020/reports/Final%20Report%20dated%2014.1.2020.pdf>

¹¹ The median is a better choice as the FRC value is susceptible to a small number of extreme values, or outliers. These outliers are possible when incorrect information regarding the exact quantum of load/generation lost in the control area is received for an FRC event.

Typically, the accuracy level of the SCADA Remote Terminal Unit (RTU) is 0.5%. Also, there is a chance of error in the instrumentation and communication. Inherent latency and non-simultaneous reporting of SCADA might also cause metering error. Hence, while calculating ACE using the RTU metered tie-line flows, there is a probability of metering errors corrupting the actual value. OFFSET shall be used if such a metering error has been established using long-term data/statistical analysis.

In case of un-observable tie-line flows, where it is not feasible to replace the actual tie line flow data manually, OFFSET can be used to substitute the tie-line flow with correct sign convention. Information of manual interventions shall be monitored, carried forward and updated frequently in every shift. Sign convention adopted for interchange MW values is, positive value for export and negative value for import. While calculating ACE, OFFSET data has to be updated/refreshed every 4 seconds.

6. Calculation of ACE

Scheduled Interchange (Is), Actual Interchange (Ia), Actual Frequency (Fa), Scheduled Frequency (Fs), Frequency Bias (Bf) and Offset shall be updated/refreshed every 4 seconds in the calculation. The formula, techniques and details have already been mentioned in the earlier sections. With the above data, ACE may be calculated every 4 seconds, i.e., refresh the value of ACE every 4 seconds.

7. Archival of different parameters

It is important to archive the individual parts of the ACE into a database every 4 seconds. That means, apart from the calculated ACE, Interchange deviation (Ia-Is), Frequency deviation (Fa-Fs), Frequency Bias (Bf) and Offset shall also be separately archived in the database every 4 seconds. This is necessary to build and calculate what-if scenarios for reserve estimation, forecasting, etc.

8. Monitoring of ACE and Suggested Corrective Actions

All the control rooms of the control areas shall prominently monitor ACE, apart from the tie-line deviation and frequency deviation.

ACE is positive means that the control area has surplus generation and the control area's internal generation has to be backed down. ACE is negative means the control area is in deficit and the control area's internal generation has to be increased. All the frequency control interventions shall be in the direction to drive ACE towards zero. ACE remaining in the same direction for several minutes without crossing zero is a strong indicator that the frequency control interventions have to be kicked in.

9. Calculating ACE for Regional Entity Control Area

Each Regional entity power station is a control area by itself. ACE for a regional entity power plant can also be worked out separately for the purpose of monitoring. The bias would depend on the number of units on bar (40% of capacity on bar per Hz assuming 5% droop plus a small load response from the unit auxiliaries). When there are fragmented control areas and virtual power plants operated from a single control center, this aspect assumes importance.

----- *****-----

Annexure-I.I

Sample Template for Frequency Response Characteristic Calculation

Frequency Response Characteristic Calculation for All India based on NLDC SCADA Data												
EVENT:	As reported at 16:02 Hrs on 11th June 2021, 220 kV Akal-Bhu -1&2 tripped due to snapping of B-phase jumper which resulted into 1200MW wind generation loss and 300MW solar generation loss in Northern region. At the same time, 400kV Barmer-Jaisalmer-1&2 also tripped due to over voltage after tripping of wind and solar generation. It appears that two events happen in quick succession, total generation loss of around 1500 MW as per reported region has been considered for FRC calculation.											
S No	Particulars	Dimension	NR	ER	WR	NER	SR	Nepal	Bhutan	#Bangladesh	Combined cross border	All India
1	Actual Net Interchange before the Event (16:02:30)	MW	11313	-5678	-8306	21.2	1850	109	1241	1039	2390	164388
2	Actual Net Interchange after the Event (16:03:50)	MW	12241	-6128	-9200	-21.5	1469	105	1241	1038	2384	164088
3	Change in Net Interchange (2 - 1)	MW	928	-451	-895	-42.7	-381	-4	-1	-1	-6	-300
4	Generation Loss (+) / Load Throw off (-) during the Event	MW	1500	0	0	0	0	0	0	0	0	1500
5	Control Area Response (3 - 4)	MW	-572	-451	-895	-43	-381	-4	-1	-1	-6	-1800
6	Frequency before the Event	HZ	50.09	50.09	50.09	50.09	50.09	50.09	50.09	50.09	50.09	50.09
7	Frequency after the Event	HZ	50.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00
8	Change in Frequency (7 - 6)	HZ	-0.090	-0.090	-0.090	-0.090	-0.090	-0.090	-0.090	-0.090	-0.090	-0.090
9	Frequency Response Characteristic (5 / 8)	MW/Hz	6353	5007	9939	475	4233	47	6	11	64	20000
10	Net System Demand met before the Event	MW	57737	18219	47210	2249	38974	--	--	--	--	--
11	Internal Generation before the Event (10 - 1)	MW	46424	23897	55516	2228	37124	--	--	--	--	--
12	Ideal load response assuming 4% per Hz (0.04*Row 10)	MW/Hz	2309	729	1888	90	1559	--	--	--	--	--
13	Ideal generator response assuming 5% droop.....40% per Hz (40% of Row 11)	MW/Hz	18570	9559	22206	891	14849	--	--	--	--	--
14	Composite ideal response (12 + 13)	MW/Hz	20879	10287	24095	981	16408	--	--	--	--	--
15	Percentage ideal response	%	30.4%	48.7%	41.2%	48.4%	25.8%	--	--	--	--	--
(*) - Data may be constant/suspected during the event Note: +ve exchange=> import ; (-)ve exchange => export		# Flow of 132kv Surjamani-comilla D/c is included in Bangladesh interchange,										Total Generation All India
Total Change in (MW)		1500										
FRC for NEWS GRID (dp/df) MW/Hz		16667										
Power Number (net change in MW/maximum change in frequency)		8824										
Source Wise Generation (MW)		GAS	HYDRO	NUCLEAR	Thermal	WIND	SOLAR					
		4834	22342	5088	98676	20669	12686					
Percentage of non responsive generation(nuclear+ wind+ solar as a percentage of total generation)						23.40%						

All-India, Region-wise and State-wise Frequency Bias Coefficient

State/Region/All India	Frequency Bias Coefficient (value in MW/0.1 Hz)
Punjab	
Haryana	
Rajasthan	
Delhi	
Uttar Pradesh	
Uttarakhand	
UT Chandigarh	
Himachal Pradesh	
UT Jammu & Kashmir	
West Bengal	
Bihar	
Odisha	
Jharkhand	
DVC	
Sikkim	
Maharashtra	
Gujarat	
Madhya Pradesh	
Chhattisgarh	
UT Dadra Nagar Haveli	
UT Daman Diu	
Goa	
Andhra Pradesh	
Tamil Nadu	
Karnataka	
Kerala	
UT Puducherry	
Telangana	
Assam	
Meghalaya	
Tripura	
Manipur	
Mizoram	
Nagaland	
Arunachal Pradesh	
ER	
NR	
NER	
SR	
WR	
All-India	

Updated as on: dd/mmm/yyyy